

**Architectural and Engineering Specification for a
Pipeline Third-Party Interference (TPI) Detection System**

FiberPatrol-PL™

This document is intended to provide performance specifications and operational requirements for the FiberPatrol-PL perimeter intrusion detection system. It is written in a generic format. These specifications may be copied verbatim to form a generic procurement specification.

Senstar and the Senstar logo are registered trademarks of Senstar Corporation. FiberPatrol and Silver Network are trademarks of Senstar Corporation. The information in this document is subject to change without notice. Senstar reserves the right to make changes to product design or manufacturing methods, as engineering progresses, or as other circumstances warrant.

Copyright © 2016. Senstar Corporation. All rights reserved.

Part 1	General	4
1.1	System Summary	4
1.2	Submittals	4
1.3	Qualifications	4
1.4	Spares.....	4
1.5	Warranty	4
1.6	References	5
Part 2	Products	6
2.1	Intrusion Detection System.....	6
2.2	Manufacturers	6
2.3	Regulatory Requirements	6
2.4	Mechanical Requirements	6
2.5	Environmental Requirements	7
2.6	Reliability and Maintenance Requirements	7
2.7	Electrical Requirements	7
2.8	Detection Capabilities	8
2.9	Cable cut response	9
2.10	Installation and Configuration Capabilities	9
2.11	Networking Capabilities	10
2.12	Event Management.....	10
2.13	Access Control.....	11
Part 3	Execution	13
3.1	Site Assessment	13
3.2	System Installation	13
3.1	System Calibration	13
3.2	Training	13

PART 1 GENERAL

1.1 System Summary

The contractor shall install a ranging third-party interference (TPI) detection system for pipelines and other in-ground infrastructure. The system shall detect and locate digging in the immediate vicinity as well as attempts to tap or damage the pipeline.

The detection sensors shall consist of fiber optic cables. The cables shall connect to a signal processing module that detects and locates attempted intrusions by analyzing the changes in reflected energy that occur as a result of minute vibrations in the sensor cables.

The system shall be capable of being integrated into the facility's Security Management System.

1.2 Submittals

A. Contractor submittals to the facility owner shall include the following as a minimum:

1. Site conditions report as per article **Error! Reference source not found.**
2. Configuration and calibration settings for the system after installation and calibration are complete as per article **Error! Reference source not found.**
3. All manufacturer-supplied software required for the calibration and operation of the system.
4. Documentation providing system operation and maintenance procedures.

1.3 Qualifications

A. The manufacturer of the system shall have a minimum of five (5) years of experience in the last 10 years of the manufacture and successful implementation of similar systems

1.4 Spares

- A. The contractor shall deliver to the facility owner spare system components.
- B. For each system component, spares consisting of at least one unit or 10% of the number that comprise the system, whichever is greater, shall be provided.

1.5 Warranty

- A. The product shall be under warranty for a minimum of two years from the date of purchase.
- B. The supplier shall make available replacement components, parts or assemblies for a minimum of 10 years from the date of purchase.

1.6 References

- A. Abbreviations and acronyms: The following acronyms and abbreviations are used in this document:
 - 1. MTBF: Mean Time Between Failures
 - 2. MTTR: Mean Time To Replace
 - 3. Pd: Probability of Detection
 - 4. TPI: Third-Party Interference
- B. Reference Standards: The following regulatory and industry standards are referenced in this document:
 - 1. Federal Communications Commission: FCC CFR Part 15, Subpart B requirements for Class A devices.
 - 2. Conformité Européenne (CE)

PART 2 PRODUCTS

2.1 Intrusion Detection System

- A. The contractor shall supply a ranging, third-party interference (TPI) monitoring system.
- B. The system shall detect and locate digging in the immediate vicinity or attempts to tap or damage the pipeline.

2.2 Manufacturers

- A. The FiberPatrol-PL™ system from Senstar Corporation (www.senstar.com) meets the requirements stated in this document.

2.3 Regulatory Requirements

- A. The system shall comply with the following regulations:
 - 1. FCC 47 CFR Part 15, Subpart B requirements for Class A devices
 - 2. CE

2.4 Mechanical Requirements

- A. Sensor cable:
 - 1. The sensor cable shall have the option to be encased in an armor jacket, for use in areas that have a high potential of physical damage to the cable.
 - 2. The sensor cable shall have a minimum bend radius no greater than 15 cm (6.0 inches).
 - 3. The sensor cable shall be installed adjacent to the pipeline.
 - 4. The sensor cable shall not require a cable conduit to be installed along the pipeline area to protect the sensor cable.
 - 5. The sensor cable shall be able to include additional, unused fibers for use by other equipment (such as for data or video communications).
 - 6. The system shall be capable of being used with pre-existing cable providing the optical fibers of the pre-existing cable meet attenuation and reflective event guidelines as set down by the system manufacturer
- B. Sensor unit equipment:
 - 1. The system shall not require any active devices or processor modules to be installed outdoors.
 - 2. All active components shall be rack-mountable in an indoor, equipment room environment
 - 3. The indoor system components shall be designed for standard 19-inch wide rack.

4. The system shall provide the option for a slide-out monitor and keyboard that enables local console access to the system.
5. The system shall include a fiber optic patch panel for interfacing the sensor cable to the processor and controller modules.

2.5 Environmental Requirements

- A. The sensor cables shall withstand operation in temperatures from -40°C to 70°C (-40°F to 158°F) and a relative humidity of 0 to 100% (condensing) without performance degradation.
- B. The sensor unit components shall be designed for indoor use and meet the following requirements
 1. Temperature:
 - a. Operating: 10°C to 35°C (50°F to 95°F)
 - b. Storage: -20°C to 70°C (-4°F to 158°F)
 2. Humidity:
 - a. Operating: 20% to 80% (relative, non-condensing)
 - b. Shipping and storage: 5% to 85% (relative, non-condensing)

2.6 Reliability and Maintenance Requirements

- A. Sensor cables: The sensor cables shall provide a nominal service life of 20 years, excluding damage caused by non-environmental forces.
- B. Sensor unit:
 1. The sensor unit modules shall have a predicted mean time between failures (MTBF) of greater than 87,000 hours.
 2. The sensor unit shall be capable of performing internal self-diagnostic tests of the internal circuitry, cable continuity, and detection processing.
 3. The sensor unit software shall be field-upgradeable, either locally via a USB connection or over the network.

2.7 Electrical Requirements

- A. Each sensor unit shall meet the following electrical requirements:
 1. Input power: 100 to 240 VAC, 50/60 Hz
 2. Power consumption: Less than 800W
- B. Backup power: The sensor unit shall be capable of being powered from a third-party uninterruptable power supply (UPS) or standby generator.
- C. The sensor cable shall include no conductive elements.
- D. The sensor cable shall be intrinsically safe within explosive atmospheres.

- E. The sensor cable shall be completely immune to all forms of electromagnetic energy from radio communications, radar, electrical power transmission equipment and lightning
- F. The system shall not require any outdoor power or grounding connections.

2.8 **Detection Capabilities**

- A. The sensor shall consist of fiber optic cable that is installed adjacent to the pipeline along the full length to be protected.
- B. The system shall be able to detect and locate pipeline third-party interference over a cable distance of up to 72 km (45 miles).
- C. The sensor unit shall have the following detection capabilities:
 - 1. Process the signal from the sensor cable to detect intruders attempting to cut, tap, drill, or otherwise interfere with the pipeline.
 - 2. Process the signal from the sensor cable to detect intruders digging within the vicinity of the protected pipeline, if buried.
 - 3. Locate the position of a detected intrusion within 10 m (33 feet) or less at least 95% of the time for typical TPI intrusions.
 - 4. Detect multiple simultaneous intrusions, when each intrusion attempt is separated by a sensor cable distance greater than 45 m (150 feet).
 - 5. Support up to 10 virtual detection zones per km (16 zones per mile).
 - 6. Be capable of detecting and locating a sensor cable cut to within 30 m (100 feet).
 - 7. Utilize adaptive algorithms in the detection process to optimally discriminate between actual intrusions and environmental activity.
- D. Intrusion detection performance:
 - 1. The probability of detection (Pd) for typical interference with the pipeline shall be 95% with a 95% confidence factor, when the system is installed in accordance with the manufacturer's directions.
 - 2. False alarm rate: The maximum rate for alarms generated by the internal electronic processes of the processors (cables excluded) shall be less than one per zone per year, averaged over the total number of zones in the system.
 - 3. Nuisance (environmental) alarms:
 - a. The system when calibrated according to manufacturer's guidelines shall not suffer nuisance alarms from any of the following sources:
 - .1 Temperature changes
 - .2 Sunrise/sunset
 - .3 Acoustic or magnetic effects
 - .4 Snow

- .5 Fog
 - .6 Wind
 - .7 Rain and hail
 - .8 Sandstorms
 - .9 Seismic vibration caused by nearby vehicular traffic
 - .10 Seismic vibration caused by nearby rail traffic when the pipeline is further than 5 m (16 feet) from the rails.
- b. The system shall utilize advanced processing and ambient compensation to minimize the probability of nuisance alarms from the following sources:
 - .1 Motion of nearby objects or vegetation
 - .2 Motion of surface or ground water
- 4. Time to detection:
 - a. The system shall be capable of generating an alarm within one minute from the onset of a detectable interference event.

2.9 Cable cut response

- A. The system shall be capable of detecting and locating a sensor cable cut.
- B. The cut location shall be determined and reported with an absolute accuracy of equal to or less than 30 meters (100 feet).
- C. In the event of a sensor cable cut, the system shall retain detection and location ability in the portion(s) of the sensor cable that remain connected to the system sensor unit.

2.10 Installation and Configuration Capabilities

- A. The system shall have the following characteristics, as a minimum:
 - 1. The sensor cable shall be capable of being buried directly adjacent to the pipeline without needing to be put in a conduit.
 - 2. The system shall support the use of non-sensing, "lead in" cable as part of the overall licensed length-limit of the system.
- B. The system shall support a cut-immune deployment configuration in which both sides of the sensor cable continue to detect interference events after a cut occurs.
- C. The system shall support the following configuration and calibration features:
 - 1. A Windows-based graphical user interface (GUI), accessible locally or via Windows Remote Desktop.
 - 2. Configuration and calibration settings shall be capable of being stored in a computer file for record keeping purposes and available for reuse when configuring additional or replacement processors.

2.11 Networking Capabilities

- A. Network manager tools: The system's network management software shall provide the following tools to facilitate system commissioning and trouble-shooting:
 - 1. System status tool that provides a visual display of the status of all processors in the system
 - 2. System event log tool that provides a searchable log of system events.
- B. The processors shall support an Ethernet RJ-45 connector as a physical media option for communication with the integrated sensor network.
- C. Network management:
 - 1. The system shall include network management software to manage the communications over the sensor network. The network management software shall be capable of running on a standard Windows PC as well as on the sensor unit itself and be accessible via Windows Remote Desktop.
 - 2. The system's network management software shall provide a TCP/IP-based interface for communicating alarm, status, and configuration data to and from security management systems. The system supplier shall furnish complete documentation of this interface to facilitate integration with security management systems.

2.12 Event Management

- A. The system shall provide a local PC-based operator interface with graphical alarm annunciation at the sensor unit.
- B. The system shall provide access to the following information and functionality when in a local or networked configuration:
 - a. A user-configurable image depicting the protected site with a schematic perimeter overlay.
 - b. Hardware monitoring and control
 - c. Event detection and alarm generation (including flashing notification message, location marker, and audible alert)
 - d. Basic alarm management
 - e. Event and alarm logging
 - f. Detection zone definition and configuration
 - g. Adjustment of detection parameters
- C. The system shall support the following alarm management functions:
 - 1. Maintain complete information on all alarms for 24 hours or until the alarm is cleared.
 - 2. Alarms shall be cleared by local or remote operator or automatically in 24 hours after alarm generation.

3. Until cleared, the alarm information shall be compiled in a scrollable multi-column table.
4. The maintained information shall include
 - a. Unique alarm ID number
 - b. Time label
 - c. Event duration
 - d. Event status
 - e. Event strength
 - f. Event location
5. Operator shall be able to
 - a. Select any of the alarms from the list
 - b. Enter text notes regarding the cause of the alarm and the mitigation measures
 - c. Clear the alarm
6. Operator notes as well as the alarm clearing event shall be recorded in the event log.
7. Alarm location Format:
 - a. The primary format of the alarm location shall be the linear position along the sensor cable
 - b. It shall be possible to express the alarm location in either meters or feet
 - c. Secondary location formats shall be derived from the primary measure using appropriate calibration tables.
 - d. Secondary location formats shall require corresponding mapping of the perimeter fence line.
 - e. It shall be possible to provide secondary alarm location formats including:
 - .1 Software-defined zones
 - .2 Latitude and longitude (GPS) coordinates
8. Event logging:
 - a. The system shall maintain and display an event log, including alarms, system notifications, and user actions.
 - b. The logs shall be periodically saved to the hard drive.
 - c. A new set of log files shall be generated every 24 hours at midnight

2.13 Access Control

- A. The system shall require the entry of a valid password at start-up and shutdown.

- B. The system shall divide user access into to three security levels:
 - 1. Operator level for routine operation
 - 2. Supervisor level for advanced system monitoring, configuration, and troubleshooting
 - 3. Installer level for advanced configuration and troubleshooting

PART 3 EXECUTION

3.1 Site Assessment

- A. Before installation begins, the installation contractor shall provide a report to the facility's owner documenting any site conditions that may prevent the system from operating satisfactorily.

3.2 System Installation

- A. The system shall be installed in accordance with the manufacturer's recommended procedures as defined in the manufacturer's documentation for the system.

3.1 System Calibration

- A. The installation contractor shall calibrate the system in accordance with the manufacturer's recommended procedures as defined in the manufacturer's Product Guide.
- B. The installation contractor shall submit to the owner the calibration and configuration settings for the system.

3.2 Training

- A. The installation contractor or vendor shall train the owner's maintenance personnel in the calibration and system maintenance procedures as given in the manufacturer's product documentation.